



# Vista Labs

Analytical • Biological • Environmental  
An ISO 9001:2008 Certified Company



Regn. No. 60Q13445

# 4-9-6, Flat No. 103 & 104,  
Surya Towers, Adj. ANR Gardens,  
HMT Nagar, Nacharam,  
Hyderabad - 500 076.  
Tele Fax : 040-27173815,  
Ph : 040-42210081,  
E-mail : vistolabs@yahoo.co.in

## TEST CERTIFICATE

Name & Address of the customer

M/s.

SUN SCHOOL  
VIZIANAGRAM  
Location: Ring Road

Lab. Ref. No. : **VIS/1263/2023**

Issue Date : **23/06/2023**

Your Ref. : ----

Received Date : **20/06/2023**

Sample Particulars :

Test Method: As per IS: 14543

## TEST RESULTS

S.No.	Parameter	Units	Values	Desirable Potable limits
1.	pH	:	7.20	6.50 – 8.50
2.	Electrical conductivity	micro mhos	49	---
3.	Dissolved solids	mg/l	24	<500
4.	Turbidity	NTU	00	<05
5.	Total Hardness as CaCO <sub>3</sub>	mg/l	02	<300
6.	Alkalinity to Phenolphthalein as CaCO <sub>3</sub>	mg/l	01	---
7.	Alkalinity to methyl orange as CaCO <sub>3</sub>	mg/l	00	<200
8.	Non- Carbonate hardness as CaCO <sub>3</sub>	mg/l	01	---
9.	Calcium as Ca	mg/l	04	<75
10.	Magnesium as Mg	mg/l	01	<30
11.	Sodium as Na	mg/l	02	---
12.	Potassium as K	mg/l	01	---
13.	Chloride as Cl	mg/l	00	<250
14.	Sulphate as SO <sub>4</sub>	mg/l	00	<200
15.	Nitrate as NO <sub>3</sub>	mg/l	00	<45
16.	Fluoride as F	mg/l	00	<1.00
17.	Silica as SiO <sub>2</sub>	mg/l	---	---
18.	Iron as Fe	mg/l	0.2	<0.3
19.	Colour	:	Colourless	Colourless

  
Authorised Signatory

Offers Analytical, Biological & Environmental Services for : Water, Industrial Effluents, Food Materials, Soils, Poultry & Animal Feeds, Ores & Minerals, Ferrous & Non-Ferrous Alloys, Rice Bran, Petroleum Products etc.